

PRODUCT **400TU Series Curtainwall**
 2-1/2" x 7 1/2" (dual IGU, aluminum pressure plates)

TEST RESULTS

Condensation Resistance Factor Frame	CRF_F	80
Condensation Resistance Factor Glass	CRF_G	72
Thermal Transmittance (BTU/hr-ft ² -°F)	U-FACTOR	0.32
Unit Size : 78-3/4" x 78-3/4" (glazed wall configuration)		
Glass makeup: 1" IGU ¼" PPG Solarban 70XL #2 ½" 90% Argon, TGI spacer ¼" Clear		

TEST LAB

ATI
 York, PA 17406

Report Number	E6650.02-116-46
Test Date	5/13/2015
Report Date	8/20/2015

Reference ATI report # E6650.02-116-46 dated 8/20/15 for complete test specimen description and data.

Tubelite Representative:

 (sign) 12/5/2017 (date)
Tim Fookes - Vice President of Engineering (title)

TEST METHODS

Thermal Performance: AAMA 1503-09, Voluntary Test Method for Thermal Transmission and Condensation Resistance of Windows, Doors, and Glazed Wall Sections.