

PRODUCT **4500 Series Storefront**
 1-3/4" x 4-1/2" (non-thermal)

TEST RESULTS

Sound Transmission Class	STC	28
Outdoor – Indoor Transmission Class	OITC	27
Unit Size : 78-3/4" x 78-1/8" (glazed wall configuration)		
Glass makeup: 1/4" monolithic		

TEST LAB

INTERTEK – ATI
 York, PA 17406

Report Number	F5707.01-113-11
Test Date	02/29/16
Report Date	03/16/16

Reference ATI report in above table for complete test specimen description and data.

Tubelite Representative:  (sign) 2/18/2018 (date)
 Tim Fookes - Vice President of Engineering (title)

TEST METHODS

ASTM E90-09: Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements

ASTM E413-10: Standard Classification for Rating Sound Insulation

ASTM E1332-10a: Standard Classification for Rating Outdoor-Indoor Sound Attenuation