

PRODUCT **T14000 IO Series Storefront Outside Plane SSG**
 2" x 4-1/2" (thermally broken)

TEST RESULTS

Thermal Transmittance (BTU/hr-ft ² -°F)	U-FACTOR	0.43
Condensation Resistance Factor Frame	CRF_F	64
Condensation Resistance Factor Glass	CRF_G	63
Unit Size : 78-3/4" x 78-3/4" (glazed wall configuration)		
Glass makeup: 1" IGU 1/4" clear 1/2" air, AZON Warm-Light Spacer 1/4" PPG Sungate 500 #3 (e=0.215)		
head, sill, jambs: P&D vertical: SSG post (E14326)		

TEST LAB

INTERTEK – ATI
 York, PA 17406

Report Number	B6924.02-116-46
Test Date	05/08/12
Report Date	06/19/12

Reference ATI report #B6924.02-116-46, dated 06/19/2012, for complete test specimen description and data.

Tubelite Representative:  (sign) 1/10/2017 (date)
 Tim Fookes - Director of Engineering (title)

TEST METHODS

Thermal Performance: AAMA 1503-09, Voluntary Test Method for Thermal Transmission and Condensation Resistance of Windows, Doors, and Glazed Wall Sections.