

PRODUCT **300ES Series Curtainwall**
 2-1/4" x 6" (high performance thermally broken)

TEST RESULTS

Sound Transmission Class	STC	31
Outdoor – Indoor Transmission Class	OITC	26
Unit Size : 80-3/16" x 80" (glazed wall configuration)		
Glass makeup: 1" IGU 1/4" clear tempered 1/2" air, aluminum spacer 1/4" clear tempered		

TEST LAB

Architectural Testing Inc.
(ATI)
 York, PA 17406

Report Number	87721.01-113-11
Test Date	12/02/2008
Report Date	12/23/2008

Reference ATI report in above table for complete test specimen description and data.

Tubelite Representative:  (sign) 3/09/18 (date)
 Tim Fookes - Vice President of Engineering (title)

TEST METHODS

ASTM E90-04: Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions

ASTM E413-04: Standard Classification for Rating Sound Insulation

ASTM E1332-90: Standard Classification for Rating Outdoor-Indoor Transmission Class