

PRODUCT **400 Series Curtainwall**
 2-1/2" x 7"

TEST RESULTS

		1" IGU	1" dbl lami IGU
Sound Transmission Class	STC	32	37
Outdoor – Indoor Transmission Class	OITC	26	31
Unit Size : 78-3/4" x 78-3/4" (glazed wall configuration)			
Glass makeup: 1" IGU 1/4" clear 1/2" air aluminum spacer 1/4" clear	Glass makeup: 1" double lami IGU 1/8"- .030 PVB – 1/8" clear 1/2" air aluminum spacer 1/8"- .030 PVB – 1/8" clear		

TEST LAB

ATI
 York, PA 17406

	1" IGU	1" dbl lami IGU
Report Number	01-31784.01	B9983.01-113-11
Test Date	07/15/98	06/21/12
Report Date	07/31/98	07/09/12

Reference the ATI reports in above table for complete test specimen description and data.

Tubelite Representative:  (sign) 5/30/17 (date)
 Tim Fookes - Vice President of Engineering (title)

TEST METHODS

ASTM E90: Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions

ASTM E413: Standard Classification for Rating Sound Insulation

ASTM E1332: Standard Classification for Rating Outdoor-Indoor Transmission Class